

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400

TEST REPORT

Client : Supertuft Pty Ltd
14 Prince Patrick Street
Richmond VIC 3121

Test Number : 21-003143
Issue Date : 25/08/2021
Print Date : 25/08/2021

Sample Description Clients Ref : "Custom Velour 60oz (Imagine Style)" 1960g/m2 Thickness: 12.5mm Colour: Beige/Black
Cut pile carpet tested on Dunlop Springtred Ultimate Underlay, Pure Wool

AS ISO 9239.1-2003

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source

Date of Sample Arrival 22-06-2021
Date Tested 24-08-2021

| CHF Value | 1 | 2 | 3 | Mean |
|-------------|-----|-----|-----|-----------------------|
| Length | 7.7 | 6.0 | 8.6 | 7.4 kW/m ² |
| Width | 8.6 | - | - | - kW/m ² |
| Smoke Value | 1 | 2 | 3 | Mean |
| Length | 68 | 76 | 59 | 68 % .min |
| Width | 28 | - | - | - % .min |

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

HF30 not reported as flame out time occurred before 30 minutes.

Each specimen was loose laid over Dunlop Springtred Ultimate Underlay and 6mm thick fibre reinforced cement board and clamped prior to testing.

247041

52472

Page 1 of 1



Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



Fiona McDonald
APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)
MANAGING DIRECTOR